



**TITLE 24, PART 6** 2025 CODE CYCLE

# Refrigeration

Codes and Standards Enhancement (CASE) Proposal  
Non-Residential | Refrigerated Warehouse Evaporator Efficiency

Kyle Larson  
January 31st, 2023



# Agenda

Background *2 min*

---

Market Overview and Analysis *2 min*

---

Technical Feasibility *3 min*

---

Cost and Energy Methodology *4 min*

---


Compliance and Enforcement *3 min*

---

Proposed Code Changes *2 min*

---

Discussion & Next Steps *5 min*






## Background

- Code Change Proposal
- 2022 Code Requirements
- Context and History

## Proposed Code Change

Add minimum fan-powered evaporator specific efficiency requirements for refrigeration systems in refrigerated warehouse spaces >3,000sqft using the following system designs:

- Flooded/Recirculated, or DX Ammonia
- Flooded/Recirculated or DX CO2
- DX Halocarbon



## Current Code Requirements

- Existing Requirements in Title 24, Part 6(a) do not exist for evaporator efficiency
  - Current requirements are limited to evaporator fan motor control and fraction EC motors on 120V or 230V evaporators.
- Model code requirements for evaporator efficiency (ASHRAE, ICC, Other States) do not exist
- The federal walk-in cooler freezer requirements does not impact target systems




Federal DOE walk-in Requirements apply to spaces less than 3,000sqft, which is uncommon for most refrigerated warehouses.

## Context and History

- Industrial fan-powered evaporators absorb heat from air inside cooler or freezer spaces of a refrigerated warehouse.
- Existing requirements for evaporators are mandated to have variable speed or use EC motors for fraction horsepower motors.
- Specific efficiency defined as capacity at selected rating conditions divided by power at full speed.
- Approach has been successfully deployed for many years for refrigeration condensers.
- Proposal will set a minimum requirement for these evaporator units so new units being installed are selected with low energy fans.
- Statewide CASE Team proposed same revision in the 2022 code cycle, but the CEC did not adopt due to resource constraints.



See the [2022 CASE Report](#) for more details.



## Market Overview

- Current Market Conditions
- Market Trends
- Potential Market Barriers and Solutions

# Market Overview and Analysis

## Current Market

- **Well-established market** with many evaporator manufacturers supplying new construction at varied efficiencies

## Market Trends

- Trend toward higher specific efficiency evaporators as equipment designs are optimized
- More systems utilizing low charge ammonia and CO2 refrigerant designs
- Foreign companies supplying equipment to California

## Market Barriers

- **No known market barriers.** Evaporators are already a well-established product with manufacturers offering a variety of models to fit a customers' requirements with multiple levels of efficiency.

More Ammonia and CO2 compared to conventional refrigerants with high GWP due to State and Federal regulatory changes.





## Technical Considerations

- Technical Considerations
- Potential Barriers and Solutions


# Technical Considerations

## Technical Considerations

- Consistent capacity and power rating basis across all manufacturing types
- Need to provide requirements for different refrigerants and uses, particularly for process loads which may or may not be exempt
- How to address floor mounted and penthouse units with additional pressure drop due to ducting

## Technical Barriers and Potential Solutions

- Obtaining data for evaporators at specific conditions as manufacturer testing methods have been inconsistent, generating some uncertainty in having requirements
- Manufacturer testing has improved, with more advanced testing and focus on two main types of ratings



Presented at Utility Sponsored Stakeholder Meeting on January 31, 2023 Refrigeration

11

Floor mounted and penthouse units (which hang from ceiling) would have pressure drop due to duct work, compared to ceiling hung units that do not have duct work.

Testing methods utilized commonly are AHRI-420, AHRI-410, ASHRAE Standard 33.

# Energy and Cost Impacts Per Square Foot

## *Methodology and Assumptions*

- Energy Savings Methodology and Results
- Cost Impacts Methodology
  - Incremental costs
  - Energy cost savings



# Methodology for Energy Impacts Analysis

- Methodology for per square foot energy and demand impacts:
  - Use anonymized existing equipment performance data to develop range of available evaporator efficiencies based on refrigerant type and use
  - Interview manufacturers, contractors, and end users to understand efficiency trends
  - Analyze prototypes with varying evaporator efficiency levels using DOE2.2R models from previous code cycles

Prototype Buildings	Size	System Configuration
Large Refrigerated Warehouse	92,000 sq ft	Single Stage; LT, MT Suction Groups
Small Refrigerated Warehouse	26,000 sq ft	Separate LT and MT systems

- All 16 California climate zones to be analyzed

## Assumptions for Standard and Proposed Designs

Evaporator Application	Liquid Feed Type	Refrigerant Type	Standard Design Minimum Efficiency	Proposed Design Minimum Efficiency
Freezer	Direct Expansion	Halocarbon	34 Btuh/W	40 Btuh/Watt
		Ammonia	20 Btuh/W	25 Btuh/Watt
	Flooded/ Recirculated Liquid	Ammonia	34 Btuh/W	45 Btuh/Watt
Cooler	Direct Expansion	Halocarbon	34 Btuh/W	45 Btuh/Watt
		Ammonia	20 Btuh/W	35 Btuh/Watt
	Flooded/ Recirculated Liquid	Ammonia	34 Btuh/W	50 Btuh/Watt

## Preliminary Energy Savings Estimates Per Square Foot

Evaporator Application	Liquid Feed Type	Refrigerant Type	Annual Electricity Savings (kWh/yr)	TDV Savings (kBtu/yr)
Freezer	Direct Expansion	Halocarbon	0.37 - 0.42	10.03 - 11.93
		Ammonia	0.76 - 0.94	20.84 - 30.23
	Flooded/ Recirculated Liquid	Ammonia	0.45 - 0.49	12.73 - 28.57
Cooler	Direct Expansion	Halocarbon	0.63 - 0.87	17.08 - 24.82
		Ammonia	1.95 - 2.83	53.20 - 80.29
	Flooded/ Recirculated Liquid	Ammonia	0.61 - 0.83	17.94 - 33.07

- No demand savings, due to common practice of demand response and load shedding during peak periods.
- No natural gas savings

2022 Title 24, Part 6 Final CASE Report – 2022-NR-COV-PROC2-F Refrigerated System Opportunities

Presented at Utility Sponsored Stakeholder Meeting on January 31, 2023 Refrigeration

17

## Incremental Cost Information

We will collect costs of base case technology and proposed technology:

- Collect anonymized cost data from manufacturers
- Develop average \$/Btuh/W for evaporators across different refrigerants and evaporator types to determine incremental cost associated with more efficient equipment
- Costing based on standard unit without controls, such as electronic expansion valves.

# Preliminary Cost Effectiveness

Evaporator Application	Liquid Feed Type	Refrigerant Type	Benefit-to-Cost Ratio
Freezer	Direct Expansion	Halocarbon	3.02 – 3.59
		Ammonia	3.21 – 4.66
	Flooded/ Recirculated Liquid	Ammonia	3.50 – 7.85
Cooler	Direct Expansion	Halocarbon	2.21 – 3.21
		Ammonia	2.57 – 3.88
	Flooded/ Recirculated Liquid	Ammonia	3.36 – 6.18

2022 Title 24, Part 6 Final CASE Report – 2022-NR-COV-PROC2-F Refrigerated System Opportunities

Presented at Utility Sponsored Stakeholder Meeting on January 31, 2023 Refrigeration



# Statewide Energy Impacts

## *Methodology and Assumptions*

- Statewide Energy Impacts Methodology





# Statewide Energy Impacts Methodology

The Statewide CASE Team estimates annual statewide impacts by multiplying **A x B x C**:

- A. per-sqft energy impacts (discussed in previous section)
- B. number of sqft of new construction/additions/alterations of each applicable building type
- C. portion of affected sqft in each climate zone

**Example:**

Per Unit Impacts			Affected New Construction				Statewide Energy Impacts				
Savings type	Savings per square foot		Climate Zone	Large Office sq ft	Assembly sq ft		Climate Zone	Elec Savings (GWh)	...	GHG savings (MT CO <sub>2</sub> e)	
Electricity	[X] kWh		1	100	20		1	20		1,500	
Peak demand	[X] Watts		2	1,000	1,500		2	50		3,000	
Natural gas	[X] Therms		...				...				
GHG emissions	[X] Tons CO <sub>2</sub> e		16	5,000	3,000		16	100		2,000	

## Assumptions for Statewide Savings Estimates

Building Types	2026 New Construction Forecast	% New Construction Impacted	Total New Construction Impacted
Refrigerated Warehouses	1.3M SF	100%	1.3M SF



## Compliance and Enforcement

- Design
- Permit Application
- Construction
- Inspection
- Revisions to Compliance Software

# Compliance and Verification Process



## 1. Design Phase

The design team develops refrigeration design loads and select the best system type and resulting equipment to supply required cooling. Based on system type, fan-powered evaporator specific efficiency requirements will be determined, allowing for sections to be made to meet or exceed the mandatory requirements. Manufacturer selection software to include evaporator specific efficiency to aide in appropriate selections.



## 2. Permit Application Phase

Contractor develops a set of stamped engineering plan drawings on the owner's behalf, including refrigeration system design and equipment schedules. Plan drawings incorporate Compliance Forms on selected equipment that complies with Title 24, Part 6, the AHJ provides plan check comments to correct inconsistencies or approves compliant plans and provides a building permits.



## 3. Construction Phase

Contractors install the refrigeration system as described in the approved plan drawings. The installed equipment matches what was approved and specified in the equipment schedule.



## 4. Inspection Phase

Before issuing a certificate of occupancy, the AHJ inspects the building and its various mechanical systems. The inspection phase includes an examination of the refrigeration system to verify the compliant equipment described in the approved design matches what was installed.

## Compliance and Verification

- Process will be similar to condensers and the associated condenser-specific efficiency requirements in §120.6(a)4.
- Forms documenting the design's compliance to be updated to include specific efficiency for fan-powered evaporators.
  - EnergyCodeAce.com provides a Virtual Compliance Assistant for filling out forms using a wizard.



## Market Actors

Market actors involved in implementing this measure include:

- Design engineers
- Installation contractors
- Owners/end users
- Equipment manufacturers
- Equipment manufacturer representatives



# Review of Code Language Markup

- Draft Code Change Language





# Draft Code Change Language

- Draft code language available for review in Handouts and downloadable.
- Provide Feedback to CASE Author by February 14, 2023

D. Fan-powered evaporators shall meet the evaporator specific efficiency requirements listed in TABLE 120.6-G at the conditions listed in TABLE 120.6-F. Evaporator specific efficiency is defined as the total refrigeration capacity (Btu/h) divided by the electrical input power at 100 percent fan speed. Capacity is rated at 10°F of temperature difference between the incoming air temperature and the saturated evaporating temperature. For glide refrigerants, the saturated evaporating temperature is defined as the dewpoint temperature. Input power is rated at 100% fan speed at rated temperature conditions.

**EXCEPTION to Section 120.6(a)3D:** Evaporators designed solely for the purpose of quick chilling/freezing of products, including but not limited to spaces with design cooling capacities of greater than 240 Btu/hr-ft<sup>2</sup> (2 tons per 100 ft<sup>2</sup>).

TABLE 120.6-F FAN-POWERED EVAPORATOR SPECIFIC EFFICIENCY RATING CONDITIONS

	<b>FREEZER APPLICATION</b>	<b>COOLER/DOCK APPLICATION</b>
Saturated evaporating dewpoint Temperature	-20°F	25°F
Entering air temperature	-10°F	35°F
External static pressure	0 in.WC	0 in.WC
Rating Type	Dry Coil	Dry Coil

TABLE 120.6-G FAN-POWERED EVAPORATORS - SPECIFIC EFFICIENCY REQUIREMENTS

EVAPORATOR TYPE	REFRIGERANT TYPE	MINIMUM SPECIFIC EFFICIENCY	
		COOLER/DOCK	FREEZER
Direct Expansion	Halocarbon	45 Btu/h/Watt	40 Btu/h/Watt
	Ammonia	35 Btu/h/Watt	25 Btu/h/Watt
	CO2	XX Btu/h/Watt	XX Btu/h/Watt
Flooded or Recirculated Liquid	Ammonia	50 Btu/h/Watt	45 Btu/h/Watt
	CO2	XX Btu/h/Watt	XX Btu/h/Watt

E. The applied static pressure drop for evaporators installed in refrigerated warehouses shall not exceed 0.5" water column.

**EXCEPTION to Section 120.6(a)3E:** Areas within refrigerated warehouses that are designed solely for the purpose of quick chilling/freezing of products (space with design cooling capacities of greater than 240 Btu/hr-ft<sup>2</sup> (2 tons per 100 ft<sup>2</sup>)).



## Discussion and Next Steps

## We want to hear from you!

- Provide **any last comments or feedback** on this presentation now verbally or over the chat
- More information on pre-rulemaking for the 2025 Energy Code at <https://www.energy.ca.gov/programs-and-topics/programs/building-energy-efficiency-standards/2025-building-energy-efficiency>

**Comments on this measure are due by February 14, 2023.** Please send comments to [info@title24stakeholders.com](mailto:info@title24stakeholders.com) and copy CASE Authors (see contact info on following slide).

**Thank  
You**

**Kyle Larson**  
VaCom Technologies  
909-392-6704 x110  
KLarson@VaComTech.com

